

**IRRIGATION DESIGN AND INSTALLATION AT COLCHESTER RECPLEX
RFP 2022-004**

ADENDUM 2

Please find requested information below

1. Addendum 1 contains 2 maps from the Town of Colchester engineering department. They are not an “as built” and should not be considered as such. They can, however, be used as guidance in developing an installation plan.
2. Water line - 8 inch
3. Depth of water line - 5 ft
4. Type of pipe (water line) - ductile iron class 52
5. How the pipe was terminated – It is not connected to map a loop on our potable water system
6. Static pressure -60 PSI
7. Booster Pump(s)- electrician will need to install conduit from supply to booster pump pad (include this in proposal).
8. Taps- anything over 2” needs to be install by approved contractor on Colchester Water Department list. 2” taps and under will be installed by Colchester Water Department.
9. Meter Pit- required per specifications from Colchester Water Department.
10. Meter- supplied by Colchester Water Department.
11. Backflow Devise- required

4/29/22 TQ