

FIELD REPORT

PROJECT: Colchester Senior Center 15 Louis Lane Colchester, CT 06415	FIELD REPORT No: 10
General Contractor: BRD Builders LLC	ARCHITECT'S PROJECT NO: 20-003

DATE: 07/31/2023 **TIME:** 01:00PM **WEATHER:** Clear **TEMP:** 80 degrees **% COMPLETE:** 08%

COPIES TO: OWNER ARCHITECT CONTRACTOR CA

The following is a summary of construction progress on the referenced project. Items for correction may also be included. (Failure to list an item of work that is required by the Construction documents does not relieve the Contractor of his responsibility to complete the same to the satisfaction of the Owner and Architect.)

ON SITE: Concrete contractor

GENERAL OBSERVATIONS AND REMARKS:

- Below slab conduit installation is ongoing.
- The remaining below slab rough plumbing PVC piping installation is ongoing and yet to be backfilled.
- The cast iron piping below the kitchen area has heat trace installed.
- The concrete footings inside the building along column lines 5, 6 and 11 are in place.
- Below slab stone is placed from column line 1 up to column line 6.
- Most of the anchor bolts are in place.
- Foundation wall penetration sealant is not in place currently.
- Catch basin installation has progressed on the South side of the building.
- The grease trap is in place.
- The large hole adjacent to Lebanon Avenue has been backfilled.

PHOTOGRAPHS: 07/31/2023







REPORT BY: Bob Washburn/SP+A Construction Administration

SILVER PETRUCELLI & ASSOCIATES, INC.

Distribution: Rob L, Ryan C/BRD; Tony/Colchester Senior Center; Michael J, John G, Mark G/CSG; Chris N, Dave S/SP+A, File